

#### BASIX Notes

#### Hot Water

The applicant must install the following hot water system in the development: Gas Instantaneous

#### Lighting

The applicant must ensure a minimum of 40% of new or altered light fixtures are fitted with fluorescent, compact fluorescent, or light-emitting-diode (LED) lamps.

#### Fixtures

The applicant must ensure new or altered showerheads have a flow rate no greater than than 9 litres per minute or a 3 star water rating.

The applicant must ensure new or altered toilets have a flow rate no greater than 4 litres per average flush or a minimum 3 star water rating.

The applicant must ensure new or altered taps have a flow rate no greater than 9 litres per minute or minimum 3 star water rating.

## Insulation Requirements

The applicant must construct suspended floor with enclosed subfloor: framed (RO.7).

Additional insulation of R1.00 down (or R1.70 including construction)

The applicant must ensure the external wall: Clad Framed is to have additional insulation of R1.30 (or R1.70 including construction)

The applicant must ensure the flat ceiling, pitched roof is to have additional insulation of ceiling: R3.50 (up), roof: foil/sarking and also medium (solar absorptance 0.475-0.70)

### Glazing Requirements

The applicant must ensure all new or altered glazed windows and/or doors have standard aluminium, clear/air gap/clear, (or U-value: 7.63, SHGC: 0.75) and Comfort Plus (U-value 5.7: SHGC: 0.47)





				J
				Р
				2
А	JUNE 2021	G.D.	ISSUED FOR APPROVAL	SCALI
REV	DATE	BY	DESCRIPTION	CKD:

# J & J TINK


# PROPOSED ALTERATIONS AND ADDITIONS 27 COURT STREET MUDGEE

27 COURT STREET MUDGEE				
SCALE:	1:300	FILE: 3701-A01	DWG No.	REV
DRAWN:	G.D.	DATE: JUNE 2021	3701 101	٨

DATE: JUNE 2021

3701-A01 A





# TYPICAL SECTION

Scale 1:50



J AND J TINK

PROPOSED ALTERATIONS & ADDITIONS 27 COURT STREET MUDGEE

> REV. Α

SCALE: 1:100	FILE: 3701-A01	DWG No.
DRAWN: G.D.	DATE: JUNE 2021	3701-A04
KD: J.T.	DATE: JUNE 2021	3101-A04