

Fire Safety Schedule

Owner: HOT ENGINEERING - H Bryant and T Goundrey

Building Name: HOT ENGINEERING

Address of Building: 10 Industrial Avenue Mudgee NSW 2850

Date: 15th August 2021

Fire Safety Measure	Design/Installation Standard	Minimum Standard of Performance	Existing installation	Proposed Installation	Not Applicable
Access panels, doors and hoppers to fire resisting shafts	BCA Clause C3.13	BCA Clause C3.13	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Automatic fail safe device	BCA Part D2	BCA Part D2	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Automatic fire detection and alarm systems	BCA Clause C2,3, E2.2, G3.8 & Specification E2.2a	AS 1670 (2004) AS 3786 (1993) as applicable	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Automatic fire suppression systems	BCA Clause E.5, C2.3, C3.11, E2.2, Specification C1.1, Parts E2, G3 & NSW Part H101	AS 2118.1 (1999) AS 2118.4 (1995) AS 2118.6 (1995) As applicable	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Emergency lighting	BCA Clause E4.2 & E4.4	AS/NZS 2293.1 (2005)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency lifts	BCA Clause E3.4	AS 1735.2 (2001) AS 1735.1 (2003) AS 1735.11 (1986)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Emergency warning and intercommunication systems	BCA Clause E4.9	AS 1670.4 (2004) AS 4428.4 (2004)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Exit signs	BCA Clause E4.5, E4.6 & E4.8	AS/NZS 2293.1 (2005)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Fire control centers and rooms	BCA Clause E1.8 & Specification E1.8	BCA Specification E1.8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Fire dampers	BCA Clause C3.12, C3.15, E1.8, Specification E1.8 Part E2 & NSW Part H101	AS/NZ 1668 Part 1 (1998)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Fire doors	BCA Clause C2.13, C3.2, C3.3, C3.4, C3.5, C3.6, C3.7, C3.8, C3.10, C3.11 D2.8, E1.8 Specification E1.8, Parts G3 & NSW H101	BCA Specification C3.4 AS/NZ 1905.1 (1997) (fire doors) AS 1905.2 (2005) (fire shutters) AS 1735.11 (1986), as applicable	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Fire hydrant systems	BCA Clause E1.3	AS 2419.1 (2005)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Fire seals protecting opening in fire resisting components of the building	BCA Part C3 & Specification C1.1	BCA Part C3 & Specification C1.1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Fire Safety Measure	Design/Installation Standard	Minimum Standard of Performance	Existing installation	Proposed Installation	Not Applicable
Fire shutters	BCA Clause C3.2 & C3.4	AS 1905.2 (2005) & Specification C3.4	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Fire windows	BCA Clause C3.2 & C3.4, C3.3, C3.8, C3.11	BCA Specification C3.4	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Hose reel systems	BCA Clause E1.4	AS 2441 (2005)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Lightweight construction	BCA Clause C1.8 & Specification C1.1	BCA Specification C1.1 & C1.8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Mechanical air handling systems	BCA Parts E2, F4, & G3 Clauses E1.8, E2.2, C2.3, D1.7 & Specification E1.8	AS/NZ 1668.1 (1998) BCA Specifications E2.2a, E2.2b, E2.2c & G3.8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Perimeter vehicle access for emergency vehicles	BCA Clause C2.3, C2.4	BCA Clause C2.3, C2.4	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Portable fire extinguishers	BCA Clause E1.6	AS 2444 (2001)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Safety curtains in proscenium openings	BCA NSW Part H101	BCA NSW Part H101	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Smoke and heat vents	BCA Clause C2.3, C2.2 Parts G3 & NSW Part H101	BCA Specification C2.2c & AS 26665 (2001)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Smoke dampers	BCA Clause C2.5, E2.2	AS/NZ 1668.1 (1998)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Smoke and heat detectors	BCA Clause E2.2 & Specification E2.2a	AS 1670 (2004) AS 3786 (1993) as applicable	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Smoke doors	BCA Clause C2.5, C2.14, D1.7 & D2.6	BCA Specification C3.4	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solid core doors	BCA Clause C3.11	BCA Clause C3.11	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Stand by power systems	BCA Clause E1.8 BCA Part G3	BCA Specification E1.8 & G3.8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wall wetting sprinkler and drencher systems	BCA Clause C3.2, C3.4, C3.11, BCA Parts G3, NSW Part H101 & Specification G3.8	BCA Clause C3.4 & As 2118.2	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Warning and operations signs	Environmental Planning & Assessment Act 1979 and Regulations	Environmental Planning & Assessment Act 1979 and Regulations	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Note:

1. This list must contain the fire safety measures existing and proposed in the whole of the building.
2. At least one in every twelve (12) month period, the owner of the building submit to Council and the NSW Fire Commissioner, a Fire Safety Certificate, in accordance with Clause 177 of the Environmental Planning and Assessment Regulation 2000.

Signed: 

Date: 15/8/21.