TEAR OUT AND ATTACH THIS BUSH FIRE ASSESSMENT REPORT WITH YOUR APPLICATION TO COUNCIL

SECTION TWO

BUSH FIRE ASSESSMENT REPORT

PART A: Property details
Applicant name: COLIN SHAPLAND
Contact phone numbers Home: Mobile:
Council: MID WESTERN REGIONAL COUNCIL
Council reference (if known):
Lot:
DP: 574851
Address to be developed: 5571 HILLEND RD HARCRAVES 285
My property is on Bush Fire Prone Land: Yes X No
PART B: Type of proposal
Type of Proposal: REBUILD
New Building X Urban Isolated Rural Rural Residential X
Alteration/Additions to an existing building
Proposal Description: e.g. two storey house with attached
SINGLE STOREY HOUSE
Copy of plans attached: Yes X No

PART C: Bush fire attack and level of construction

Step 1

Assess the vegetation hazard in all directions

Category	North	East	South	West
Keith vegetation	Rainforest	Rainforest	Rainforest	Rainforest
group	Forest	Forest	Forest	Forest
	Grassy and Semi-Arid Woodland	Woodland	Woodland	Woodland
	Forested Wetland	Forested Wetland	Forested Wetland	Forested Wetland
	Tall Heath	Tall Heath	Tall Heath	Tall Heath
	Short Heath	Short Heath	Short Heath	Short Heath
	Arid-Shrubland	Arid-Shrubland	Arid-Shrubland	Arid-Shrubland
	Freshwater Wetlands	Freshwater Wetlands	Freshwater Wetlands	Freshwater Wetlands
	Grasslands	Grasslands	Grasslands	Grasslands
	(Managed Land)	(Managed Land)	(Managed Land)	(Managed Land

Copy of any relevant photos attached:

Voc	X
res	

No

Step 2

Determine the distance from the building to the bush fire vegetation hazard

		We
Distance > loo_m > loo_m	7.100.m60.m	60

Step 3 Determine the effective slope that will influence bush fire behaviour in each direction

North

Category	North	East	South	West
Slope under the hazard (over 100m)	upslope/flat	upslope/flat	upslope/flat	upslope/flat
[in degrees]	S	(Olos)	>0 to 5	>0 to 5
	>5 to 10	>5 to 10	>5 to 10	>5 to 10
	>10 to 15	>10 to 15	>10 to 15	>10 to 15
	>15 to 20	>15 to 20	>15 to 20	>15 to 20
FFDI: 100 Step 5	80 🗶	ocal government area.		
Match the relevant FF Identify the BAL for ϵ BAL-12.5 is the lowest	each direction, select	the highest level for t	the entire building and	L. d record below. Note
Bush Fire Attack Leve	2,000,000	BAL- 29	BAL-12.5	x ,
Step 6				
Determining BAL con	struction requiremen	nts		
	BAL has been determ	mined in Stan E ACZO	59-2018 and or/ the Noosed design.	IASH Standard 2014 will
Does your proposal m NASH Standard (2014)	eet the construction			.S3959-2018 and the

Grassland Deeming Provisions Assessment

This assessment is only required where the deeming provisions are to be used. Where the deeming provisions are not to be used, previous Steps 1 to 6 in Part C must be applied. Tick which box below applies to individual

An APZ of 50m or more can be provided at the
An APZ of 50m or more can be provided - this can be considered to meet PBP 2019, no further bush fire protection measures are required
An APZ of 20-49m can be provided – comply with Grassland Deeming Provisions requirements in the
An APZ of less than 20m is provided or the standard assessment process is proposed - use the assessment process identified in Steps 1 to 6 above

Grassland Deeming Provisions

BUSH FIRE PROTECTION MEASURE	GRASSLAND DEEMING PROVISIONS	
	limited to a maximum of 15 degrees downslope;	
APZ	minimum APZ of 20m is provided between the building and unmanaged grass;	
	the APZ is wholly within the boundaries of the development site; and	
	the APZ is maintained as a mown area with grass heights less than 100mm.	
Construction	construction in accordance with BAL-12.5 of AS3959-2018 and any additional construction requirements in PBP 2019.	
Access	comply with the property access provisions in Part G.	
Water supply	comply with the water supply provisions in Part E.	
Landscaping	 comply with the relevant provisions in Appendix 4 of PBP 2019, noting that other vegetation bush fire hazards cannot be present if these provisions are to apply. 	

PART D: Flame zone

Provide details and justification for any additional bush fire protection measures required for a performance based solution.

PART E: Water supplies

Does your property have a reticulated water supply?; If so, please provide details on the distance to the nearest fire hydrant on your site plan.

Reticulated water supply is available:

Yes No X

Distance (m) to hydrant from house.

Do you have or do you plan to have a dedicated water supply for firefighting purposes?

Yes 🗴 No

Development Type	Water Requirement	Planned	Existing
Residential Lots (<1,000m²)	5,000 I/lot		
Rural-residential Lots (1,000 - 10,000m²) <1 ha	10,000 I/lot		
Large Rural/Lifestyle Lots (>10,000m²) >1 ha	20,000 I/lot	>54,0006	NIC
Townhouse/Unit Style (e.g. Flats including Dual Occupancy)	5,000 I/unit up to 20,000 I maximum.		

Do you have or do you plan to have a static water supply (e.g. pool, tank or dam)?

Include approximate size in litres and also include tank material if using a tank:

Water supply type	Capacity	Construction material	Planned	Existing
e.g. pool	50,0001	Above ground rolled steel with plastic liner	59,000	LIL

NOTE: Check with your local council concerning their Local Environmental Plan (LEP) or their Development Control Plan (DCP) as this may dictate the type and size of tank.

PART F: Gas supplies Do you have reticulated or bottled gas? Type of gas: Reticulated gas: Bottled gas: NOTE: When attaching development plans please ensure they clearly show location and details of electricity and gas (where relevant) on your property.

Part G: Access

Does the development proposal meet the requirements as defined in this document?



Date: 20/03/2023

Map Scale: 1:2770 at A4

Mid-Western