

SEWER TREATMENT PLANTS - Environmental Compliance										01 April 2023 -31 March 2024				
Rylstone Sewage treatment Works Crawell Street, Rylstone 2849 NSW Environment Protection Licence: 1958 <a href="http://www.epa.nsw.gov.au/prpoeoapp/">http://www.epa.nsw.gov.au/prpoeoapp/</a>														
Monitoring Point 3 Pollutant		pH	EC	TDS (calculated)	TSS	Chlorine total residual	Total Nitrogen	Total Phosphorus	Chlorophyll a	Oil & Grease	BOD	Faecal Coliforms	Report Generated	Comments
Limits		6.5-8.5			50	0.5	35	10		10	30			
Units			µs/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/m3	mg/L	mg/L	CFU/100mL		
Date sampled	Date results received													
12/04/2023	19/04/2023	7.9	713	478	16	<0.2	4.2	4.23	49	<2	2	3800	21/04/2023	
10/05/2023	19/05/2023	7.7	696	466	14	<0.2	5.4	3.30	38	<1	10	830	23/05/2023	
				0										
				0										
				0										
				0										
				0										
				0										
				0										
				0										
				0										
				0										
				0										
No of samples taken		2	2	11	2	2	2	2	2	2	2	2		
Samples/year required by EPA		Monthly (12)			Monthly (12)	Monthly (12)	Monthly (12)	Monthly (12)		Monthly (12)	Monthly (12)	Monthly (12)		
Minimum		7.7	696	0	14.0	0.1	4.2	3.30	38	1.0	2.0	830		
Average		7.8	705	86	15.0	0.1	4.8	3.77	44	1.0	6.0	2315		
Maximum		7.9	713	477.71	16	0.1	5.4	4.23	49	1.0	10	3800		
Samples within limits (%)		100			100	100	100	100		100	100			

SEWER TREATMENT PLANTS - Environmental Compliance													01 April 2023 -31 March 2024	
Rylstone Sewage treatment Works Crawell Street, Rylstone 2849 NSW Environment Protection Licence: 1958 <a href="http://www.epa.nsw.gov.au/prpoeoapp/">http://www.epa.nsw.gov.au/prpoeoapp/</a>														
Monitoring Point 4		pH	EC	TDS (calculated)	TSS	Chlorine total	Total Nitrogen	Total Phosphorus	Chlorophyll a	Oil & Grease	BOD	Faecal Coliforms	Report Generated	Comments
Pollutant			µs/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/m3	mg/L	mg/L	CFU/100mL		
Units														
Date sampled	Date results received													
12/04/2023	19/04/2023	<0.2											21/04/2023	
10/05/2023	19/05/2023	<0.2											23/05/2023	
No of samples taken		0	0	0	0	2	0	0	0	0	0	0		
EPA required frequency (samples per year)		Annual	(1)		Annual (1)	Monthly (12)	Annual (1)	Annual (1)		Annual (1)	Annual (1)	Annual (1)		
Minimum		0.0												
Average		0.0												
Maximum		0.1												

SEWER TREATMENT PLANTS - Environmental Compliance										01 April 2023 -31 March 2024				
Rylstone Sewage treatment Works Crawell Street, Rylstone 2849 NSW Environment Protection Licence: 1958 <a href="http://www.epa.nsw.gov.au/prpoeoapp/">http://www.epa.nsw.gov.au/prpoeoapp/</a>														
Monitoring Point 5		pH	EC	TDS (calculated)	TSS	Chlorine total	Total Nitrogen	Total Phosphorus	Chlorophyll a	Oil & Grease	BOD	Faecal Coliforms	Report Generated	Comments
Pollutant			µs/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/m3	mg/L	mg/L	CFU/100mL		
Units														
Date sampled	Date results received													
12/09/2022		0												
No of samples taken		0	0	0	1	1	0	0	0	1	1	1		
EPA required frequency (samples per year)		Annual (1)			Annual (1)		Annual (1)	Annual (1)		Annual (1)	Annual (1)	Annual (1)		

SEWER TREATMENT PLANTS - Environmental Compliance      01 April 2023 -31 March 2024						
Rylstone Sewage treatment Works						
Crawell Street, Rylstone 2849 NSW						
Environment Protection Licence: 1958						
Monitoring Point 1		Total	Month within Limits (%)	No of reading taken	Number of reading required	Comments
Frequency: daily						
Limits		100 ML/Year (100000 KL/Year)				
Units	Report Generated	KL	KL			
Month						
April	1/05/2023	2823	100	30	30	
May			0	31	31	
June			0	30	30	
July			0	31	31	
August			0	31	31	
September			0	30	30	
October			0	31	31	
November			0	30	30	
December			0	31	31	
January			0	31	31	
February			0	28	28	
March			0	31	31	
Yearly TOTAL		2823	100	365	365	