

SEWER TREATMENT PLANTS - Environmental Compliance													01 April 2021 -31 March 2022	
Gulgong Wastewater Treatment Plant 107 Spring Creek Road, Gulgong NSW 2852 Environment Protection Licence: 5808 http://www.epa.nsw.gov.au/prpoeoapp/														
Monitoring Point 3		pH	EC	TDS (calculated)	TSS	Chlorine total residual	Total Nitrogen	Total Phosphorus	Chlorophyll a	Oil & Grease	BOD	Faecal Coliforms	Report Generated	Comments
Pollutant		6.5-9.5			50	1	40	10		10	20	1000		
Limits			µs/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/m3	mg/L	mg/L	CFU/100mL		
Units														
Date sampled	Date results received													
13/04/2021	21/04/2021	8.1	1030	690	6	<0.2	1.9	3.68	6	<2	3	65	22/04/2021	
26/05/2021	2/06/2021	8.0	1030	690	4	<0.2	2.7	3.98	2	<2	3	20	3/06/2021	
29/06/2021	6/07/2021	8.1	986	661	2	<0.2	2.3	3.68	1	<2	<2	1	7/07/2021	
20/07/2021	28/07/2021	8.4	972	651	2	<0.2	2.0	3.29	2	<2	<2	<1	29/07/2021	
23/08/2021	30/08/2021	8.9	962	645	6	<0.2	1.5	3.09	10	<2	<2	1	30/08/2021	
15/09/2021	23/09/2021	9.5	935	626	16	<0.2	1.1	2.81	4	<2	<2	3	23/09/2021	
13/10/2021	20/10/2021	10.0	904	606	2	<0.2	0.8	1.17	<1	<2	<2	19	21/10/2021	Algae present in pond
15/11/2021	22/11/2021	10.2	890	596	2	<0.2	0.8	0.62	2	<2	<2	2	23/11/2021	Algae present in pond
14/12/2021	21/12/2021	9.9	845	566	2	<0.2	0.7	0.90	1	<2	4	9	22/12/2021	Algae present in pond
13/01/2022	20/01/2022	9.5	838	561	2	<0.2	0.9	1.40	<1	<2	<2	79	24/01/2022	
16/02/2022	23/02/2022	9.5	895	600	3	<0.2	0.8	1.89	2	<2	<2	31	24/02/2022	
16/03/2022	22/03/2022	9.2	882	591	4	<0.2	1.0	2.53	2	<2	<2	33	23/03/2022	
No of samples taken		12	12	12	12	12	12	12	10	12	12	11		
Samples/year required by EPA		12			12	12	12	12		12	12	12		
Minimum		8.0	838	561	2.0	0.1	0.7	0.62	1	1.0	1.0	1		
Average		9.1	931	624	4.3	0.1	1.4	2.42	3	1.0	1.6	24		
Maximum		10.2	1030	690	16	0.1	2.7	3.98	10	1	4	79		
Samples within limits (%)		75			100	100	100	100		100	100	100		

SEWER TREATMENT PLANTS - Environmental Compliance		01 April 2021 -31 March 2022						
Gulgong Wastewater Treatment Plant 107 Spring Creek Road, Gulgong NSW 2852 Environment Protection Licence: 5808								
Monitoring Point 1		Min	Max	Average	Month within Limits (%)	No of reading taken	Number of reading required	Comments
Frequency: daily								
Limits								
Units	Report Generated	KL	KL	KL	KL			
Month								
April	14/05/2021	312	358	332	100	30	30	
May	1/06/2021	333	506	362	100	31	31	
June	6/07/2021	349	1103	444	100	30	30	
July	3/08/2021	345	685	402	100	31	31	
August	2/09/2021	312	438	350	100	31	31	
September	6/10/2021	308	517	340	100	30	30	
October	3/11/2021	246	503	330	100	31	31	
November	1/12/2021	293	1706	502	100	30	30	
December	6/01/2022	263	2345	629	100	31	31	
January	2/02/2022	282	1717	441	100	31	31	
February	3/03/2022	222	378	319	100	28	28	
March	1/04/2022	307	1773	552	100		31	