

SEWER TREATMENT PLANTS - Environmental Compliance										01 April 2025 -31 March 2026					
Gulgong Wastewater Treatment Plant 107 Spring Creek Road, Gulgong NSW 2852 Environment Protection Licence: 5808 http://www.epa.nsw.gov.au/prpoeoapp/															
Monitoring Point 2		pH	EC	TDS (calculated)	TSS	Chlorine total residual	Total Nitrogen	Total Phosphorus	Chlorophyll a	Oil & Grease	BOD	Faecal Coliforms	Report Generated	Comments	
Pollutant															
Limits															
Units				µs/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/ m3	mg/L	mg/L	CFU/100mL		
Date sampled	Date results received														
16/04/2025	28/04/2025	9.3	1030	690	12	<0.2	1.4	2.54	10	<2	3	20	29/04/2025		
14/05/2025	22/05/2025	8.9	1040	697	4	<0.2	1.4	2.69	8	<2	3	28	27/05/2025		
11/06/2025	20/06/2025	8.3	995	667	9	<0.2	2.1	2.44	1	<2	2	5	20/06/2025		
No of samples taken		3	3	3	3	3	3	3	3	3	3	3			
Samples/year required by EPA		12			12	12	12	12		12	12	12			
Minimum		8.3	995	667	4.0	0.1	1.4	2.44	1	1.0	2.0	5			
Average		8.8	1022	685	8.3	0.1	1.6	2.56	6	1.0	2.7	18			
Maximum		9.3	1040	697	12	0.1	2.1	2.69	10	1	3	28			

SEWER TREATMENT PLANTS - Environmental Compliance										01 April 2025 -31 March 2026					
Gulgong Wastewater Treatment Plant 107 Spring Creek Road, Gulgong NSW 2852 Environment Protection Licence: 5808 http://www.epa.nsw.gov.au/prpoeoapp/															
Monitoring Point 5		pH	EC	TDS (calculated)	TSS	Chlorine total	Total Nitrogen	Total Phosphorus	Chlorophyll a	Oil & Grease	BOD	Faecal Coliforms	Report Generated	Comments	
Pollutant		6.5-9.5			30	1	15	5		10	10	600			
Limits			µs/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/m3	mg/L	mg/L	CFU/100mL			
Units															
Date sampled	Date results received														
16/04/2025	28/04/2025	Not Discharging											29/04/2025		
14/05/2025	22/05/2025	Not Discharging											27/05/2025		
11/06/2025	20/06/2025	Not Discharging											20/06/2025		
No of samples taken		0	0	0	12	12	0	0	0	12	12	12			
Samples/year required by EPA		12			12	12	12	12		12	12	12			
Minimum		0.0	0	0	#NUM!	#NUM!	0.0	0.00	0	#NUM!	#NUM!	#NUM!			
Average		#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!			
Maximum		0	0	0	0	0.0	0.0	0.00	0	0	0	0			
Samples within limits (%)		#DIV/0!			0	0	#DIV/0!	#DIV/0!		0	0	0			

SEWER TREATMENT PLANTS - Environmental Compliance										
01 April 2025 -31 March 2026										
Gulgong Wastewater Treatment Plant 107 Spring Creek Road, Gulgong NSW 2852 Environment Protection Licence: 5808										
http://www.epa.nsw.gov.au/prpoeoapp/										
Monitoring Point 4		Site no and depth	Exchangeable Calcium	Exchang. Magnesium	Exchang. Sodium	Salinity	pH (CaCl2)	Total Nitrogen	Total Phosphorus	Sodium Adsorptio
Pollutant										
Units			mg/Kg	mg/Kg	mg/Kg	mg/Kg		mg/Kg	mg/Kg	
Date sampled	Date results received									
No of samples taken		0	0	0	0	0	0	0	0	0
EPA required frequency (samples per year)		Annual (1)	Annual (1)	Annual (1)	Annual (1)	Annual (1)	Annual (1)	Annual (1)	Annual (1)	Annual (1)

SEWER TREATMENT PLANTS - Environmental Compliance										
01 April 2025 -31 March 2026										
Gulgong Wastewater Treatment Plant 107 Spring Creek Road, Gulgong NSW 2852 Environment Protection Licence: 5808										
Monitoring Point 1		Min	Max	Average	No of reading taken	Number of reading required		Comments		
Frequency: daily										
Limits										
Units	Report Generated	KL	KL	KL						
Month										
April	7/05/2025	266	525	307	30	30				
May	2/06/2025	259	2134	388	31	31				
June					30	30				
July					31	31				
August					31	31				
September					30	30				
October					31	31				
November					30	30				
December					31	31				
January					31	31				
February					28	28				
March					31	31				