

SEWER TREATMENT PLANTS - Environmental Compliance										01 April 2025 -31 March 2026				
Kandos Sewage treatment Works Rylstone Road Kandos NSW 2848 Environment Protection Licence: 1737 http://www.epa.nsw.gov.au/prpoeoapp/														
Monitoring Point 3 Pollutant		pH	EC	TDS (calculated)	TSS	Chlorine total residual	Total Nitrogen	Total Phosphorus	Chlorophyll a	Oil & Grease	BOD	Faecal Coliforms	Report Generated	Comments
Limits		6.5-8.5			50	0.5	35	10		10	30			
Units				µs/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/m3	mg/L	mg/L	CFU/100mL	
Date sampled	Date results received													
15/04/2025	24/04/2025	7.9	1150	771	12	<0.2	17.9	7.68	<1	<2	8	65	24/04/2025	
13/05/2025	21/05/2025	7.9	1210	811	7	<0.2	25.8	10.00	6	4	3	<1	27/05/2025	
12/06/2025	20/06/2025	8.0	1150	771	6	<0.2	28.7	5.80	2	<2	4	550	20/06/2025	
No of samples taken		3	3	3	3	3	3	3	2	3	3	3		
Samples/year required by EPA		12			12	12	12	12		12	12	12		
Minimum		7.9	1150	771	6	0.1	17.9	5.80	2	1.0	3.0	65		
Average		7.9	1170	784	8	0.1	24.1	7.83	4	2.0	5.0	308		
Maximum		8	1210	810.7	12	0.1	28.7	10.00	6	4	8	550		
Samples within limits (%)		100			100	100	100	100		100	100			

SEWER TREATMENT PLANTS - Environmental Compliance					01 April 2025 -31 March 2026			
Kandos STP								
Rylstone Road Kandos NSW 2848								
Environment Protection Licence: 1737								
Monitoring Point 1		Min	Max	Average	Month within Limits (%)	No of reading taken	Number of reading required	Comments
Frequency: daily								
Limits		1800 KL/Day	1800 KL/Day	1800 KL/Day	1800 KL/Day			
Units	Report	KL	KL	KL	KL			
Month	Generated							
April	7/05/2025	262	471	337	100	30	30	
May	2/06/2025	297	938	365	100	31	31	
June					100	30	30	
July					100	31	31	
August					100	31	31	
September					100	30	30	
October					100	31	31	
November					100	30	30	
December					100	31	31	
January					100	31	31	
February					100	28	28	
March					100	31	31	