

SEWER TREATMENT PLANTS - Environmental Compliance														01 April 2025 -31 March 2026	
Rylstone Sewage treatment Works Carwell Street, Rylstone 2849 NSW Environment Protection Licence: 1958 http://www.epa.nsw.gov.au/prpoeoapp/															
Monitoring Point 3		pH	EC	TDS (calculated)	TSS	Chlorine total residual	Total Nitrogen	Total Phosphorus	Chlorophyll a	Oil & Grease	BOD	Faecal Coliforms	Report Generated	Comments	
Pollutant		6.5-8.5			50	0.5	35	10		10	30				
Limits			µs/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/m3	mg/L	mg/L	CFU/100mL			
Units															
Date sampled	Date results received														
15/04/2025	23/04/2025	9.9	749	502	36	<0.2	6.8	3.64	149	<2	16	580	24/04/2025	Elevated pH due to algae growth	
13/05/2025	21/05/2025	7.8	884	592	15	<0.2	11.3	8.14	8	3	8	280	27/05/2025		
12/06/2025	20/06/2025	8.0	891	597	9	<0.2	19.0	4.63	22	<2	11	340	20/06/2025		
				0											
				0											
				0											
				0											
				0											
				0											
				0											
				0											
				0											
				0											
No of samples taken		3	3	12	3	3	3	3	3	3	3	3			
Samples/year required by EPA		Monthly (12)			Monthly (12)	Monthly (12)	Monthly (12)	Monthly (12)		Monthly (12)	Monthly (12)	Monthly (12)			
Minimum		7.8	749	0	9.0	0.1	6.8	3.64	8	1.0	8.0	280			
Average		8.6	841	141	20.0	0.1	12.4	5.47	60	1.7	11.7	400			
Maximum		9.9	891	596.97	36	0.1	19	8.14	149	3.0	16	580			
Samples within limits (%)		67			100	100	100	100		100	100				

SEWER TREATMENT PLANTS - Environmental Compliance										01 April 2025 -31 March 2026				
Rylstone Sewage treatment Works Carwell Street, Rylstone 2849 NSW Environment Protection Licence: 1958 http://www.epa.nsw.gov.au/prpoeoapp/														
Monitoring Point 4		pH	EC	TDS (calculated)	TSS	Chlorine total	Total Nitrogen	Total Phosphorus	Chlorophyll a	Oil & Grease	BOD	Faecal Coliforms	Report Generated	Comments
Pollutant			µs/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/m3	mg/L	mg/L	CFU/100mL		
Units														
Date sampled	Date results received													
15/04/2025	23/04/2025	<0.2											24/04/2025	
13/05/2025	21/05/2025	<0.2											27/05/2025	
12/06/2025	20/06/2025	<0.2											20/06/2025	
No of samples taken		0	0	0	0	3	0	0	0	0	0	0		
EPA required frequency (samples per year)		Annual	(1)		Annual (1)	Monthly (12)	Annual (1)	Annual (1)		Annual (1)	Annual (1)	Annual (1)		
Minimum		0.0												
Average		0.0												
Maximum		0.1												

SEWER TREATMENT PLANTS - Environmental Compliance										01 April 2025 -31 March 2026				
Rylstone Sewage treatment Works Carwell Street, Rylstone 2849 NSW Environment Protection Licence: 1958 http://www.epa.nsw.gov.au/prpoeoapp/														
Monitoring Point 5		pH	EC	TDS (calculated)	TSS	Chlorine total	Total Nitrogen	Total Phosphorus	Chlorophyll a	Oil & Grease	BOD	Faecal Coliforms	Report Generated	Comments
Pollutant			µs/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/m3	mg/L	mg/L	CFU/100mL		
Units														
Date sampled	Date results received													
No of samples taken		0	0	0	1	1	0	0	0	1	1	1		
EPA required frequency (samples per year)		Annual (1)			Annual (1)		Annual (1)	Annual (1)		Annual (1)	Annual (1)	Annual (1)		

SEWER TREATMENT PLANTS - Environmental Compliance 01 April 2023 -31 March 2024						
Rylstone Sewage treatment Works						
Carwell Street, Rylstone 2849 NSW						
Environment Protection Licence: 1958						
Monitoring Point 1		Total	Month within Limits (%)	No of reading taken	Number of reading required	Comments
Frequency: daily						
Limits		100 ML/Year (100000 KL/Year)				
Units	Report Generated	KL	KL			
Month						
April	7/05/2025	2763	100	30	30	
May	2/06/2025	3009	100	31	31	
June			0	30	30	
July			0	31	31	
August			0	31	31	
September			0	30	30	
October			0	31	31	
November			0	30	30	
December			0	31	31	
January			0	31	31	
February			0	28	28	
March			0	31	31	
Yearly TOTAL			0	365	365	