

SEWER TREATMENT PLANTS - Environmental Compliance										01 April 2025 -31 March 2026					
Gulgong Wastewater Treatment Plant 107 Spring Creek Road, Gulgong NSW 2852 Environment Protection Licence: 5808 http://www.epa.nsw.gov.au/prpoeoapp/															
Monitoring Point 2		pH	EC	TDS (calculated)	TSS	Chlorine total residual	Total Nitrogen	Total Phosphorus	Chlorophyll a	Oil & Grease	BOD	Faecal Coliforms	Report Generated	Comments	
Pollutant															
Limits															
Units				µs/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/ m3	mg/L	mg/L	CFU/100mL		
Date sampled	Date results received														
16/04/2025	28/04/2025	9.3	1030	690	12	<0.2	1.4	2.54	10	<2	3	20	29/04/2025		
14/05/2025	22/05/2025	8.9	1040	697	4	<0.2	1.4	2.69	8	<2	3	28	27/05/2025		
11/06/2025	20/06/2025	8.3	995	667	9	<0.2	2.1	2.44	1	<2	2	5	20/06/2025		
No of samples taken		3	3	3	3	3	3	3	3	3	3	3			
Samples/year required by EPA		12			12	12	12	12		12	12	12			
Minimum		8.3	995	667	4.0	0.1	1.4	2.44	1	1.0	2.0	5			
Average		8.8	1022	685	8.3	0.1	1.6	2.56	6	1.0	2.7	18			
Maximum		9.3	1040	697	12	0.1	2.1	2.69	10	1	3	28			

SEWER TREATMENT PLANTS - Environmental Compliance										01 April 2025 -31 March 2026					
Gulgong Wastewater Treatment Plant 107 Spring Creek Road, Gulgong NSW 2852 Environment Protection Licence: 5808 http://www.epa.nsw.gov.au/prpoeoapp/															
Monitoring Point 5		pH	EC	TDS (calculated)	TSS	Chlorine total	Total Nitrogen	Total Phosphorus	Chlorophyll a	Oil & Grease	BOD	Faecal Coliforms	Report Generated	Comments	
Pollutant		6.5-9.5			30	1	15	5		10	10	600			
Limits			µs/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/m3	mg/L	mg/L	CFU/100mL			
Units															
Date sampled	Date results received														
16/04/2025	28/04/2025	Not Discharging											29/04/2025		
14/05/2025	22/05/2025	Not Discharging											27/05/2025		
11/06/2025	20/06/2025	Not Discharging											20/06/2025		
No of samples taken		0	0	0	12	12	0	0	0	12	12	12			
Samples/year required by EPA		12			12	12	12	12		12	12	12			
Minimum		0.0	0	0	#NUM!	#NUM!	0.0	0.00	0	#NUM!	#NUM!	#NUM!			
Average		#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!			
Maximum		0	0	0	0	0.0	0.0	0.00	0	0	0	0			
Samples within limits (%)		#DIV/0!			0	0	#DIV/0!	#DIV/0!		0	0	0			

SEWER TREATMENT PLANTS - Environmental Compliance				01 April 2025 -31 March 2026						
Gulgong Wastewater Treatment Plant										
107 Spring Creek Road, Gulgong NSW 2852				Report generated: 18/09/2024						
Environment Protection Licence: 5808				http://www.epa.nsw.gov.au/prpoeoapp/						
Monitoring Point 4		Site no and depth	Exchangeabl e Calcium	Exchang. Magnesium	Exchang. Sodium	Salinity	pH (CaCl2)	Total Nitrogen	Total Phosphorus	Sodium Adsorptio
Pollutant										
Units			mg/Kg	mg/Kg	mg/Kg	mg/Kg		mg/Kg	mg/Kg	
Date sampled	Date results received									
No of samples taken			0	0	0	0	0	0	0	0
EPA required frequency (samples per year)			Annual (1)	Annual (1)	Annual (1)	Annual (1)	Annual (1)	Annual (1)	Annual (1)	Annual (1)

SEWER TREATMENT PLANTS - Environmental Compliance					01 April 2025 -31 March 2026			
Gulgong Wastewater Treatment Plant 107 Spring Creek Road, Gulgong NSW 2852 Environment Protection Licence: 5808								
Monitoring Point 1 Frequency: daily		Min	Max	Average	No of reading taken	Number of reading required		Comments
Limits								
Units	Report Generated	KL	KL	KL				
Month								
April	7/05/2025	266	525	307	30	30		
May	2/06/2025	259	2134	388	31	31		
June	2/07/2025	313	877	407	30	30		
July					31	31		
August					31	31		
September					30	30		
October					31	31		
November					30	30		
December					31	31		
January					31	31		
February					28	28		
March					31	31		